

M-RCK:ef

9 May 1957

Corps of Engineers, U.S. Army
Building 198
Fort Monmouth, New Jersey

Att: (b)(6)

Dear (b)(6)

On the AAA Facilities, drawing file #9604-743, your contractor relocated the guard house and electrical utilities. The electrical utility wire to the guard house was extended across the railroad from pole #516. This condition has caused the pole to lean towards the railroad.

It is requested that a guy wire be installed on pole #516 to provide proper support.

Very truly yours,

(b)(6)

LCDR, GEC, USN
Public Works Officer

RCK
5/9